

Annexure C

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY
CONDITION CERTIFICATE.**

Number - 05

Date - 06/01/2025

It is certified that an inspection team headed by Mr. Deepak khare (Name of Officers with designation) from asstt. Engineer phc ^{Jabalpur} (Name of Department/Office) inspected the **G. D. Goenka International School, Jabalpur, Khasra No. 233, 53/3 Barela Highway Road, Jabalpur** on 06/01/2025 (date of inspection) and on the basis of water test report (attached) bearing on R.No.-128 dated 03/01/2025 Of district water testing laboratory (PHED LAB) Certified that the **G. D. Goenka International School**, (name of school) Has safe drinking water facilities for the students and member of staff of the institution. school is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the central state U.T GOVT.
The certificate is valid till 06/07/2025

To **G. D. Goenka International School, Jabalpur (M.P.)**
(name and address of the institution)

**Assistant Engineer
P.H.E. Sub-Division**

Signature with Seal: **Jabalpur**

Name: **Mr. Deepak Khare**

Designation: **Assistant Engineer
AE, PHED, Jabalpur (M.P.)**

not : the certificate is to be issued by authorized officer /
phed lab / local bodies

DISTRICT WATER TESTING LABORATORY
Office of the Executive Engineer, Public Health Engg. Division Jabalpur M.P.

WATER TESTING REPORT

Report No. 138	Date 03-01-2025	District Jabalpur	Code No. 73/1	Block
Ref. NO. -	Date 02-01-2025	Village & Location		
To, G.D. Goenka International School, Near Ekta Market, Barela By Pass Road, JABALPUR (M.P.)				
Sample Collected by Neeraj Sharma	Date of collection 02-01-2025	Source R.O. Water		
Date of receipt 02-01-2025	Date of Testing 03-01-2025	Test conducted by Poochima Soni		

As per BIS 10500:2012 Reaffirmed in feb 2021 For Drinking Water

Sl no.	Characteristic	Unit	Acceptable	Cause for rejection	RESULT				
					1	2	3	4	5
PHYSICAL TEST									
1	Turbidity	NTU	1.0	5.0	1.0				
2	Colour	Pt. Cobalt							
3	Test & Odour	Unobjectionable	Unobjectionable						
CHEMICAL TEST									
4	pH	...	6.5 to 8.5	6.5 to 8.5	8.90				
5	Conductivity	p Mohs/cm			31				
6	Alkalinity	mg/l	200	600	220				
7	Chloride (As Cl)	mg/l	250	1000	30				
8	Nitrates	mg/l	45	45	0.0				
9	Total Hardness (As CaCO ₃)	mg/l	200	600	500				
10	Calcium (As Ca)	mg/l	75	200	100.0				
11	Magnesium (As Mg)	mg/l	30	100	60.74				
12	Total dissolved solid	mg/l	500	2000	59				
13	Iron (As Fe)	mg/l	1.00	1.0	0.0				
14	Manganese (As Mn)	mg/l	0.10	0.30	0.0				
15	Fluoride (As F)	mg/l	1.00	1.50	0.84				
16	Sulphates As SO ₄	mg/l	200	400	0.31				
17	Residual Chlorine	mg/l	0.20	1.0					
BACTERIOLOGICAL TEST									
18	Total Coliform	per 100ml	0						
19	E Coli or Thermo tolerant coliforms	per 100ml	0						

Note:- 1. As above result compared with BIS 10500:2012

2. Samples are not collected by us.

3. Not to be produced at court of law.

4. We do not take any responsibility for deviation in test result due to wrong collection of sample

Poochima Soni
03-01-2025
ANALYST
Public Health Engg. Division
Jabalpur District Laboratory
P.H.E. Dn. Jabalpur